

# Load Break Disconnecter Switch

## DGL-125A-4000A Load Break Switch-Front Operation

**GEICO**<sup>®</sup>

### Cutoff Function:

Power supply changeover Main power supply changeover to stand by power  
Changeover, reverse Changeover between two load equipment. (Emergency standby  
motor) Reversion by two phases changeover  
Bypass circuit Full bypassing isolates the equipment from upstream and downstream  
currents (With one operation)  
Cutoff + the grounding One operation of grounding and short circuit realizes the  
isolation(\*) ( $U_e > AC$ ) General cutoff function meets standards of IEC947 and GB/T14048

